

Addendum No. 1

Date: **September 11, 2023**

Re: **Playground Equipment – Bryson Elementary**

IFB No.: **324-23-9-21**

The following information becomes part and parcel of Invitation for Bid (IFB) #324-23-9-21 effective this date. Firms must acknowledge receipt of this addendum in their solicitation response.

The listed items add to, modify, or otherwise alter the specifications and become part of the solicitation documents. Where a portion of the original specifications are added to, modified, or also altered, the portion not so affected shall remain. Firms may have the right to protest this addendum.

Inquiries/ District Responses

Before the solicitation inquiry deadline, the District received an inquiry regarding this solicitation. The District's response to the question follows in **bold** font.

1.) GCSD implemented a program that all new playgrounds are required to have Grassmats or an equal to be installed after the mulch has been installed to provide greater accessibility for the entire playground. Is this a requirement on this project as well?

Contractor to use existing grassmats and rearrange as required for new equipment. Additional grassmats should be provided as needed. For new monkey bar location, new grassmats are to be provided. (See photos in bid package for existing conditions).

2.) Will any substitutions of the grassmats have a requirement to have an impact attenuation test showing a minimum critical height of 10' when combined with IPEMA certified playground mulch?

Yes, any grassmat product is required to meet ASTM guidelines for playground surfacing impact attenuation (min 10' critical height) when combined with IPEMA certified playground mulch.

End of Section

All other terms and conditions remain unchanged and in force.

Thank you for your interest in the District.

Tonya A. Stroud

Tonya A. Stroud
Senior Buyer