



Procurement Department

2 Space Drive • Taylors, SC 29687-6072 • (864) 355-1279 •

The School District of Greenville County

Addendum No. 3

Date: May 12th, 2023

Re: ADA Playground Accessibility

IFB No.: **323-29-5-19**

The following information becomes part and parcel of Invitation for Bid (IFB) #323-29-5-19 effective this date. Firms must acknowledge receipt of this addendum in their solicitation response.

The listed items add to, modify, or otherwise alter the specifications and become part of the solicitation documents. Where a portion of the original specifications are added to, modified, or also altered, the portion not so affected shall remain. Firms may have the right to protest this addendum.

Inquiries/ District Responses

Before the solicitation inquiry deadline of May 9th, 2023, the District received inquiries regarding this solicitation. The District's response to each question follows in **bold** font.

1. Question: Need drawings S1 and S2, They are not included in the drawings currently
District Response: 4 new structural drawings were issued in Addendum #2 on Monday.
2. Question: Top of wall elevations at handicap ramps, if not shown on S1 and S2
District Response: Elevations shown on structural drawings in Addendum #2.
3. Question: Handrails are not shown on ramp at Gateway Elementary. Need a detail. IF wall does not go above top of walk then we would need a guard rail detail.
District Response: Included on structural drawings in Addendum #2.
4. Question: What type / color / make of brick?
District Response: Match existing brick on existing wall at Augusta Circle ES.
5. Question: Could masonry block walls be used in lieu of poured concrete? (Augusta Circle & Gateway) If so, will engineered drawings be provided?
District Response: Can be used as alternate. Engineering is provided by the awarded bidder and will not be provided by the district. Engineered drawings must be stamped then delivered to the district representative and 3rd party inspector for review prior to start of construction.
6. Question: Will engineering be provided for stacker block retaining walls which exceed 3'? (Sara Collins & Welcome)
District Response: 4 feet is the threshold and neither have walls at that height. Sara Collins has been reissued per addendum.

End of Section – Inquiries/District Responses

Additional District Provided Information for Addendum Three

1. Completion date for all work is August 5th, 2023. Disregard any other completion date that may be contained in the solicitation.
2. Contractor is responsible for providing their own bathroom facilities
3. Double ADA plastic ramps are not to be used. Concrete sidewalk should terminate at ground level at playground borders. Grass mats are to be used as accessible path to and around the equipment.
4. Unit price for accessible structure shall be based on referenced structure detail on the Brook Glenn Elementary site plan.
5. Revised site plan issued for Sara Collins Elementary
6. Revised Unit Pricing Bid Form issued to include unit pricing for engineered wood fiber mulch (Page 3 of Addendum)
7. Revised engineered drawings issued for Augusta Circle ES, Gateway ES, and Sara Collins ES.

All other terms and conditions remain unchanged and in force.

Thank you for your interest in the District.

Matt Pettit

Matt Pettit

Director of Procurement

Attachments (2): Add #3 Revised Civil Drawings (323-29(Drawings4))
Revised Site Plan for Sara Colling Elementary

ADA Playground Accessibility – Eleven Elementary Schools

UNIT PRICING

The undersigned proposes the following unit prices for additions to or deductions from the Contract Sum in the AGREEMENT. The Owner reserves the right to include, or not include, the following unit prices (either individually or as a whole) in the AGREEMENT. Unit prices shall include all costs for materials, labor, tools, equipment, temporary works/protection, cutting and waste, removal of packaging and surplus materials, fees, taxes, insurance, bonding, overhead, profit, etc.

Description of Work	Unit Pricing
1. ADA Swing Seat	\$ _____ / Each
2. ADA Wheelchair Platform Swing	\$ _____ / Each
3. Grassmat® ADA Compliant Path Surfacing	\$ _____ / Each
4. Ground Level Component	\$ _____ / Each
5. ADA Accessible Play Structure	\$ _____ / Each
6. Engineered Wood Fiber Mulch Fall Surfacing	\$ _____ / cubic yard
7. Black Plastic Playground Border:	
4' long x 9" tall	\$ _____ /Each
4' long x 12" tall	\$ _____ /Each
6' long x 9" tall	\$ _____ /Each
6' long x 12" tall	\$ _____ Each

Authorized Signature: _____ Date: _____

Firm Name: _____