

## **Addendum No. 1**

Date: **January 16, 2023**

Re: **LED Lighting Upgrades – Eastside High**

IFB No.: **324-54-1-23**

The following information becomes part and parcel of **Invitation for Bid (IFB) #324-54-1-23** effective this date. Firms must acknowledge receipt of this addendum in their solicitation response.

The listed items add to, modify, or otherwise alter the specifications and become part of the solicitation documents. Where a portion of the original specifications are added to, modified, or also altered, the portion not so affected shall remain. Firms may have the right to protest this addendum.

### **Clarification**

#### **Delete the following statement in the IFB:**

*Do not include South Carolina sales tax in bid pricing. The District will add South Carolina Sales Tax as applicable to purchase orders throughout the contract term.*

#### **Add/Modify the following paragraph in the IFB:**

The bid price(s) **shall include** all materials, labor, sales and other applicable taxes, rental equipment, rental tools, and consumables necessary to provide and deliver the product(s).

### **Inquiries/ District Responses**

Before the solicitation inquiry deadline, the District received an inquiry regarding this solicitation. The District's response to the question follows in **bold** font.

1.) I would just like to ask and clarify if providing alternates for the lighting fixtures are acceptable?

**The Invitation for Bid documents have a provision in the Project Manual Specifications for a Request for Substitute.**

2.) The existing fixture schedule indicates tandem wiring on some of the troffer fixtures. This normally means there is only a power /neutral wire in every other fixture with a ballast whip (18g) between fixtures. Is it the intent to run new whips to bring up to code for the new kits or fixtures? Sheet E1 Electrical General Notes #2.

**Reference Drawing E3, Lighting Fixture Schedule:**

**Clarification:**

**Where the schedule references existing tandem fixtures that are being replaced with individual fixtures, replace the existing tandem fixture whip with a new whip connected to the lighting circuit junction box. Where this length exceeds 6', extend existing circuit with EMT to new junction box to be located within 6' of fixture.**

3.) Sheet E1 Scope of work Note 4 Is there a rate we can use for your security contractor?

**Reference Specifications Section 010010, Basic Requirements, Page 9, Paragraph 1.29: Replace paragraph with the following:**

**All work to accomplish this retrofit shall occur after hours, at night, and on weekends. Contractor shall coordinate acceptable hours with school and District personnel. Contractor is responsible for hiring District's security contractor to be on site at all times work is occurring. Cost of security contractor shall be included in bid. The District's Security Contractor is Kingdom Security, contact Kester Skinner, 864-906-7202.**

**End of Section**

All other terms and conditions remain unchanged and in force.

Thank you for your interest in the District.

*Tonya A. Stroud*

Tonya A. Stroud  
Senior Buyer