

2 Space Dr., Taylors, SC 29687-6072

# Addendum No. 1

Date: May 2, 2024

# Re: **Parking Lot Renovations – Riverside High**

IFB No.: **324-99-5-13** 

The following information becomes part and parcel of **Invitation for Bid (IFB) #324-99-5-13** effective this date. Firms must acknowledge receipt of this addendum in their solicitation response.

The listed items add to, modify, or otherwise alter the specifications and become part of the solicitation documents. Where a portion of the original specifications are added to, modified, or also altered, the portion not so affected shall remain. Firms may have the right to protest this addendum.

### **Additional Drawings**

The Project Manager and Project Architect have provided updated additional drawings for clarification. The drawings may be found on the Procurement Department's website at the link below as a separate attachment:

<https://www.greenville.k12.sc.us/Departments/main.asp?titleid=solicitations>

## **Inquiries/ District Responses**

Before the solicitation inquiry deadline, the District received inquiries regarding this solicitation. The District's response to each question follows in **bold** font.

1.) I see a light pole detail, are there any light poles to relocate/install? **See Drawing C2.0, Note 1 for light pole to be relocated.** 


2.) I see the one power pole it says to relocate but it appears to be staying in the same place.

The new light pole foundation is moving approximately 10 feet to the north of its current location. For clarity it will be located 6'-0'' from the centerline of the foundation to the face of the new curb of the driveway cut-through.


3.) Also, the gates are already there, but it also has a gate detail.

See Drawing C3.0, Note 7 refers to the new proposed gate and shows the location. The new gate is located nearby the new light pole foundation. Contractor will coordinate foundations with existing conditions and utilities.

#### 4.) I highlighted a crossing below, can you tell me what that is?



See sketch below for clarification of proposed work.



#### End of Section

All other terms and conditions remain unchanged and in force. Thank you for your interest in the District.

Tonya <u>H. Stroud</u>

Tonya A. Stroud Senior Buyer