

Addendum No. 1

Date: **September 5, 2024**

Re: **Chiller Replacement – Blue Ridge High**

IFB No.: **325-21-9-10**

The following information becomes part and parcel of **Invitation for Bid (IFB) #325-21-9-10** effective this date. Firms must acknowledge receipt of this addendum in their solicitation response.

The listed items add to, modify, or otherwise alter the specifications and become part of the solicitation documents. Where a portion of the original specifications are added to, modified, or also altered, the portion not so affected shall remain. Firms may have the right to protest this addendum.

Clarifications

1. Trane Technologies is the controls sub-contractor performing installation of control wiring and devices associated with the chiller replacement work of this project, and is working directly for Greenville County Schools. The new R-513a refrigerant sensors, which replace existing refrigerant sensors, and its installation, wiring, and connection to the existing refrigerant monitor, shall be work of Trane Technologies.
2. Basis of design chiller utilizes R-513a refrigerant, which is a Safety Group A1 refrigerant. The existing exhaust system adjacent to new chiller CH-1 exceeds the requirements for the largest refrigerant charge in the chiller, which is 180.8 lbs.

End of Section

All other terms and conditions remain unchanged and in force. Thank you for your interest in the District.

Tonya A. Stroud

Tonya A. Stroud
Senior Buyer