

## **Addendum No. 1**

Date: **October 23, 2023**

Re: **Digital Sign – Berea High School**

RFP No.: **424-36-11-7**

The following information becomes part and parcel of Request for Proposal (RFP) #424-29-10-18 effective this date. Firms must acknowledge receipt of this addendum in their solicitation response.

The listed items add to, modify, or otherwise alter the specifications and become part of the solicitation documents. Where a portion of the original specifications are added to, modified, or also altered, the portion not so affected shall remain. Firms may have the right to protest this addendum.

### **Inquiries/ District Responses**

Before the solicitation inquiry deadline of **October 20, 2023**, the District received an inquiry regarding this solicitation. The District's response to each question follows in **bold** font.

1. What is the Current electrical Voltage to the Sign?

**Current voltage to existing copy board is 120V. However, this existing power is on timer/photocell, so intent is for power utility to provide new meter providing 120V (district to coordinate.)**

2. Is any landscaping required?

**Landscaping not required, however contractor is responsible for repair to any grassing/landscaping damaged during sign install.**

3. Will the brick need to be cleaned afterward ?

**Cleaning not required, however contractor is responsible for any cleanup to brick structure resulting from dirtying during install.**

**End of Section – Inquiries/District Responses**

All other terms and conditions remain unchanged and in force.

Thank you for your interest in the District.

*Valarie W. Southerlin*

Valarie W. Southerlin

Buyer I